

C/M or P/M Reviewed:		<b><u>PRE-JOB HAZARD ASSESSMENT (PJHA), SCAFFOLDING</u></b> <b>Select:</b> <b>Erector-Dismantler / User-Client</b>
----------------------	--	--

Job Location: Building & Room(s):	Contractor/Subcontractor Name:	Rev: 2018
Project:	Date:	Erector/User Name:

**Scope of Work:**

Tasks being Performed	Potential Safety Risks/Hazards	Safety Controls / Mitigations
Please identify which scaffold type you are installing:  Please identify which scaffold type you will be using.:  Give heights & lengths of the scaffold being erected or worked from:  Fall Protection is required for erecting scaffolds with the working platform over 6'	<ul style="list-style-type: none"> <li>- Risk of serious bodily injury or death</li> <li>-</li> <li>-</li> <li>-</li> <li>-</li> <li>-</li> <li>-</li> <li>-</li> <li>-</li> </ul> ... Continue on another sheet if needed	The erecting & dismantling of scaffolding shall be performed under the direction of a qualified person.  Erecting or working on scaffolds over 6' (Aff) without a guardrail system in place, fall protection will be required.  <u>Fall Protection Matrix</u> is also required when using Fall Protection equipment.  Inspections of scaffolds by a competent person shall occur after the scaffold has been erected to ensure its been properly erected and then tagged. (RED, YELLOW or GREEN.)  Scaffold placed over passageways, doorways, streets or any location where they may have activities being conducted over any other areas; need to be protected by barricades and signage to establish walkways to divert traffic away from construction areas.  Pre-shift inspections of scaffolds by a qualified person shall occur prior to the start of work or shift.  All employees shall be trained and instructed in the safe use of scaffolds with documentation of attendance.  For mobile scaffold, ensure "ALL" scaffold wheels are locked when working from the platform.
House Keeping Protocol:	Risk of slip, trips & falls	The area on, near or around scaffold are to be kept clear of any debris  Be aware of your surroundings.  Maintain proper footing & body positioning at all times

<b>Employee Signatures:</b>	<b>Date:</b>

<b>Employee Signatures:</b>	<b>Date:</b>

<b>Employee Signatures:</b>	<b>Date:</b>

**A signed copy of this PJHA must be posted while all applicable parties are working on-site and MUST be available to any employee or client upon request.**